

**OFFICE OF THE MEMBER (DRAINAGE)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
VARUNALAYA PHASE-II: KAROL BAGH
NEW DELHI-110005.**

No: F-1(7)/M(Dr.)/2014/ 553

Dated: 28.02.2014
2/3/14

MINUTES OF THE MEETING HELD IN THE CHAMBER OF MEMBER (DRAINAGE) ON 26.02.2014 AT 11.00 AM WITH SHRI NAND KISHORE GARG, MLA TO DISCUSS SEWERAGE PROBLEMS IN THE TRI NAGAR ASSEMBLY CONSTITUENCY.

Following were present: -

Delhi Jal Board:

1. Shri R.S. Tyagi, Member (Dr.)in chair
2. Shri S.L. Meena, CE(West)
3. Shri Shalabh Kumar, SE(Dr)Proj.-N&NW
4. Shri V.K. Singh, EE(NW)III
5. Shri Ajay Gupta, ZE(NW)III

Public Representatives:

1. Sh. Nand Kishore Garg, MLA (AC-16), Kothi No 10, Road No. 4, East Punjabi Bagh, Delhi.
2. Smt. Meera Aggarwal, Mpl. Councilor & Member, DJB


The following points were discussed: -

1. At the outset the public representative Shri Nand Kishore Garg, MLA, Smt. Meera Aggarwal, Mpl. Councilor & Member, Delhi Jal Board and his team were welcomed by Member (Dr.).
2. It was informed that in most of the area of the Tri Nagar Constituency, temporary trolleys are stationed for pumping of sewage due to mal-functioning the sewerage system. These trolleys are not running properly. Hence, the area of Harsh vihar, Mahendra Park, Srinagar and Raja Park etc is facing a lot of problem of sewer overflow. SE(Dr)P-N&NW informed that the work of rehabilitation of Shakur Basti – Saraswati Vihar peripheral sewer has already been taken up which has been completed to the extent of 70%. The balance work will be completed by 30th June, 2014. After rehabilitation and commissioning of the sewer, the temporary trolleys in the entire area shall be removed. Member (Dr.) directed concerned EE(E&M)W&S-N/W maintaining these temporary trolleys to supervise these trolleys personally and ensure proper pumping round the clock till the sewer line in question is made functional.

3. It was informed that in Pitampura Village the sewer line has been settled in a length of about 250 M and the residents of the area are facing problems. EE (NW)III stated that he has already sent requisition to Drainage Project Division for repair of the settled sewer. SE (Dr)Proj. N&NW assured that the settled sewer will be repaired by 15th April, 2014, by that time E&M Wing will ensure regular pumping. The log sheet of the trolleys installed should be checked by maintenance divisions regularly to ascertain that pumps are running.
4. In Harsh Vihar area, the storm water drains are connected with sewerage system, this should be checked by the EE (NW) III and disconnect all the storm water drain.
5. It was informed that there five major societies i.e. Mandakini, Ashiana, Subhavana etc. which are not connected with DJB sewer line and sewage discharges into the storm water drain. It was explained that sewerage infrastructure charges are deposited by the developing agency to DJB. Since, these societies are very old, the record of Infrastructure Development charges is not traceable. Smt. Meera Aggrawal Hon'ble Member, DJB informed that sewage is polluting River Water. DJB should find out record and connect sewer connection of these societies to prevent pollution in SW drains. She further requested that the maintenance of internal sewerage system of societies should also be taken over by DJB for maintenance. Member (Dr) informed that policy regarding maintenance of internal sewer lines of the societies is under review by Delhi Jal Board.
6. It was informed by Sh. Nang Kishore Garg, MLA that Lwarence Road CETP is not working. The sewerage system is also not functioning well. It was explained by C.E.(west) that CETPs are maintained by DSIIDC. In so far as maintenance of sewer line is concerned, the work of laying of sewer line was done by Delhi Jal Board as a deposit work on behalf of DSIIDC a long back. But, the system is still being maintained by DJB for which no separate Budget exists.
7. It was informed that sewer lines of Trinagar old area are very old and need replacement. C.E.(West) informed that the sewer lines are being replaced in a phased manner.
8. Out fall system of Golden Park: It was informed that the out fall system of Golden Park is not working and the project taken up earlier was not completed. Member (Dr) explained that Interceptor sewer line is being laid along Najafgarh drain. After completion of this work, entire area under its command will be benefitted. Small Sewage Pumping Stations

will also be removed by connecting their peripheral lines into it, as the depth of Interceptor sewer is around 40 feet and diameter is 2400 mm.

9. Member (Dr) directed all concerned to take up the works on priority. He will take another review meeting after 15 days.
10. The meeting ended with a vote of thanks to the chair.


EO to Member (Dr).

All Concerned: